



Certificate No.

IECRE.WE.TC.19.0057-R1

IECRE - IEC System for Certification to Standards Relating to Equipment for Use in Renewable Energy Applications

TYPE CERTIFICATE

Wind Turbine

This certificate is issued to

Vestas Wind Systems A/S
Hedeager 42
8200 Aarhus N
Denmark

for the wind turbine

Vestas V136-4.0 MW / V136-4.2 MW

wind turbine class (class, standard, year)

See Annex 1, IEC 61400-1: 2005+Amd1: 2010

This certificate attests compliance with IEC 61400 Series as specified in subsequent pages. It is based on the following reference documents:

Design basis evaluation conformity statement
Dated

DB-DNVGL-SE-0074-04978-1
2020-01-09

Design evaluation conformity statement
Dated

DE-DNVGL-SE-0074-04979-2
2020-01-09

Type test conformity statement
Dated

TT-DNVGL-SE-0074-04980-1
2020-01-09

Manufacturing conformity statement
Dated

ME-DNVGL-SE-0074-05446-1
2020-01-09

Final evaluation report
Dated

FER-TC-DNVGL-SE-0074-04977-1
2020-01-09

The conformity evaluation was carried out in accordance with the rules and procedures of the IECRE System www.iecre.org

The wind turbine type specification begins on page 2 of this certificate.

Changes in the system design or the manufacturer's quality system are to be approved by DNV GL. Without approval, the certificate loses its validity.

This certificate is valid until:
2025-01-08

Approved for issue on behalf of the IECRE
Certification Body:



Nils Kreidelmeyer / Bente Vestergaard
Senior Project Manager / Service Line Leader, Type
Certification
Hamburg 2020-01-09



Renewables Certification
Brooktorkai 18
20457 Hamburg, Germany



Certificate. No.

IECRE.WE.TC.19.0057-R1

IECRE - IEC System for Certification
to Standards Relating to Equipment
for Use in Renewable Energy
Applications

TYPE CERTIFICATE

Wind Turbine

Machine parameters:

Power regulation:	pitch-controlled
Rotor orientation:	Upwind
Number of rotor blades:	3
Rotor tilt:	6.0°
Cone angle:	4.0°
Rated power:	4000 kW / 4200 kW
Rated wind speed V_r :	See Annex 1
Rotor diameter:	136 m
Hub height(s):	See Annex 1
Hub height operating wind speed range $V_{in} - V_{out}$:	3.0 – 27.0 m/s (HWO disabled) 3.0 – 32.0 m/s (HWO enabled)
Design life time:	20 years
Software version:	2017.09.126

Wind conditions:

Characteristic turbulence intensity I_{ref} at $V_{hub} = 15$ m/s:	0.14
Annual average wind speed at hub height V_{ave} :	See Annex 1
Reference wind speed V_{ref} :	42.5 m/s
Mean flow inclination:	8°

Electrical network conditions:

Normal supply voltage and range:	720 V 19.1-36 kV \pm 10 %
Normal supply frequency and range:	50 or 60 Hz \pm 6 % Hz
Voltage imbalance:	IEC 61000-3-6 TR max 2 %
Maximum duration of electrical power network outages:	Two 3 months periods
Number of electrical network outages	Max 52 per year



Certificate. No.

IECRE.WE.TC.19.0057-R1

IECRE - IEC System for Certification
to Standards Relating to Equipment
for Use in Renewable Energy
Applications

TYPE CERTIFICATE

Wind Turbine

Other environmental conditions (where taken into account):

Normal and extreme temperature ranges:

*de-rating strategy above +30°C for V136-4.0 MW

*de-rating strategy above +20°C for V136-4.2 MW

Normal: -20°C to +45°C*

Extreme: -40°C to +50°C

Relative humidity of the air:

100% (max 40% of time) and
90% (rest of life time)

Air density:

1.225 kg/m³ (for normal
operation)

1.273 kg/m³ (for low
temperature operation)

1000 W/m²

Solar radiation:

Lightning protection system (standard and protection
class):

Designed acc. to IEC 61400-24,
Protection Level 1 and IEC
61312-1



Certificate. No.

IECRE.WE.TC.19.0057-R1

IECRE - IEC System for Certification
to Standards Relating to Equipment
for Use in Renewable Energy
Applications

TYPE CERTIFICATE

Wind Turbine

Major components:

**If not otherwise stated, the certificate holder is the manufacturer.

Blade:

Type:	Hybrid/Infused
Material:	Hybrid: Glass fibre pre-preg / dry glass "hybrid" and pvc core with Carbon and T pultrusions Infused: dry glass together with Carbon and T pultrusions
Blade length:	66.65 m
Number of blades:	3
Manufacturer:	Vestas
Drawing / Data sheet / Part No.:	0055-0068, Rev. 6

Blade Aero Addons:

Type	STE's and RVG's
Manufacturer	Vestas Wind Systems A/S
Drawing / Data sheet / Part no.	STE Kit: 0059-6671, Rev. 0 RVG: 0056-5767, Rev. 1

Blade bearing:

Type:	Double row four-point contact ball bearing
Manufacturer:	Laulagun/Rollix/Liebherr/TMB
Drawing / Data sheet / Part No.:	29058368, Rev.1

Pitch System:

Type:	Hydraulic power unit
Manufacturer:	LJM/Glual/Hine/Liebherr
Hydraulic Cylinder (160/90x922):	29060554, Rev. 2

Type	Pitch Actuation Module
Manufacturer	Vestas Wind Systems A/S
Drawing / Data sheet / Part no.	29113714, Rev.1



Certificate. No.

IECRE.WE.TC.19.0057-R1

IECRE - IEC System for Certification
to Standards Relating to Equipment
for Use in Renewable Energy
Applications

TYPE CERTIFICATE

Wind Turbine

Main shaft:

Type: Cast iron
Material: EN-GJS-500-14
Drawing / Data sheet / Part no.: 29085300, Rev. 4

Main bearing:

Type: Spherical Roller Bearing
Manufacturer: FAG
Drawing / Data sheet / Part no.: F-582562.PRL-WPO 000

Main bearing:

Type: Spherical Roller Bearing
Manufacturer: SKF
Drawing / Data sheet / Part no.: 240/950 CA / C3LW33VQ113

Main bearing:

Type: Spherical Roller Bearing
Manufacturer: JTKET / KOYO
Drawing / Data sheet / Part no.: 240/950 RHAW33TS1CS

Gearbox:

Type: 2 stage planetary and helical stage
gearbox
Manufacturer: ZF (EH1052A)
Gear ratio: 1:137
Drawing / Data sheet / Part no.: 096-EH1052A001, Rev. A

Type: 2 stage planetary and helical stage
gearbox
Manufacturer: Winergy (PZAB 3580)
Gear ratio: 1:137.66
Drawing / Data sheet / Part no.: A5E45622888A, rev.2



Certificate. No.

IECRE.WE.TC.19.0057-R1

IECRE - IEC System for Certification
to Standards Relating to Equipment
for Use in Renewable Energy
Applications

TYPE CERTIFICATE

Wind Turbine

Yaw System:

Drive type: 8 x 2.7 kW, 400 V, 50 Hz asynchronous
motors
Drive manufacturer: Lafert
Drawing / Data sheet / Part no.: MZ10/A4A-55337

Drive type: 8 x 3.2 kW, 400 V, 60 Hz asynchronous
motors
Drive manufacturer: Lafert
Drawing / Data sheet / Part no.: MZ10/A4A-55338

Drive type: 8 x 2.7 kW, 400 V, 50 Hz asynchronous
motors
Drive manufacturer: ABB
Drawing / Data sheet / Part no.: 3GZF500810-23 A 14 AA 100 A

Drive type: 8 x 3.2 kW, 400 V, 60 Hz asynchronous
motors
Drive manufacturer: ABB
Drawing / Data sheet / Part no.: 3GZF500810-23 A 14 AA 100 A

Drive type: 8 x 2.7 kW, 400 V, 50 Hz asynchronous
motors
Drive manufacturer: Bonfiglioli
Drawing / Data sheet / Part no.: CD00006614-02

Drive type: 8 x 3.2 kW, 400 V, 60 Hz asynchronous
motors
Drive manufacturer: Bonfiglioli
Drawing / Data sheet / Part no.: CD00007013-01

Gear type: Bevel stage and three planetary stages, i
= 952.3
Gear manufacturer: Bonfiglioli
Drawing / Data sheet / Part no.: I7090T010300



Certificate. No.

IECRE.WE.TC.19.0057-R1

IECRE - IEC System for Certification
to Standards Relating to Equipment
for Use in Renewable Energy
Applications

TYPE CERTIFICATE

Wind Turbine

Gear type: Bevel stage and three planetary stages, i
= 935
Gear manufacturer: Comer
Drawing / Data sheet / Part no.: N07297_01

Bearing type: Preloaded sliding bearing, PETP pads
Bearing manufacturer: Vestas Wind Systems A/S
Drawing / Data sheet / Part no.: 29104726, Rev. 0

Generator:

Type: DASG 560/6M, Induction generator
Manufacturer: Vestas Nacelles Deutschland (VND)
Rated power: 4450 kW
Rated frequency: 74 Hz
Rated speed: 1485 rpm
Rated voltage: 800 V
Rated current: 3650 A
Insulation class: H
Degree of protection: IP54

Converter:

Type: Full quadrant IGBT
Manufacturer: Vestas Wind Systems A/S
Rated voltage machine/grid: 720 Vrms / 800 Vrms
Rated current: 3200 A
Degree of protection: IP54
Drawing / Data sheet / Part no.: 0069-2805, Rev. 0

Transformer:

Type: Cast-Resin transformer
4GY6781-1EY
Manufacturer: Siemens
Rated voltage: 33 / 0.72 kV



Certificate. No.

IECRE.WE.TC.19.0057-R1

IECRE - IEC System for Certification
to Standards Relating to Equipment
for Use in Renewable Energy
Applications

TYPE CERTIFICATE

Wind Turbine

Degree of protection: IP00
Drawing / Data sheet / Part no.: 0073-7914, Rev. 0

Type: Cast-Resin transformer
DTTH1N 4000/30
Manufacturer: SGB
Rated voltage: 33 / 0.72 kV
Degree of protection: IP00
Drawing / Data sheet / Part no.: 0073-7915, Rev. 0

Tower:

Type: Conical steel
Number of sections: 5
Length: 109.60 m (HH 112 m)
Drawing / Data sheet / Part no.: 0072-0565 Rev. 0 (T887005)

Tower:

Type: Conical steel
Number of sections: 4
Length: 79.60 m (HH 82 m)
Drawing / Data sheet / Part no.: 0060-8092 Rev. 0 (T3111520)

Tower:

Type: Conical steel
Number of sections: 3
Length: 79.60 m (HH 82 m)
Drawing / Data sheet / Part no.: A005-3045 Rev. 0 (T885209)

Tower:

Type: Conical steel
Number of sections: 5
Length: 114.60 m (HH 117 m)
Drawing / Data sheet / Part no.: A006-0555 Rev. 1 (T887501)



Certificate. No.

IECRE.WE.TC.19.0057-R1

IECRE - IEC System for Certification
to Standards Relating to Equipment
for Use in Renewable Energy
Applications

TYPE CERTIFICATE

Wind Turbine

Manuals:

Operating manual:	0079-9811, Rev. 1
Transportation and handling manual:	0079-9801, Rev. 2
Installation manual:	0079-9663, Rev. 2
Commissioning manual:	0079-9665, Rev. 0

Service lift:

Manufacturer:	Avanti
Type:	Avanti Shark / Avanti Dolphin / Avanti Beluga

Manufacturer:	Power climber
Type:	Sherpa-SD4

Crane:

Manufacturer:	Star 071/95 Liftket
Maximum lifting capacity:	max 800 kg



Certificate. No.

IECRE.WE.TC.19.0057-R1

IECRE - IEC System for Certification
to Standards Relating to Equipment
for Use in Renewable Energy
Applications

TYPE CERTIFICATE
Wind Turbine

Annex 1

Configurations covered by this Type Certificate

ID*	Variants	Hub Height	IEC WT class	Turbulence Intensity I _{ref}	Rated wind speed V _r	Mean wind speed V _{ave}
1.1	V136-4.0 MW	82 (T3111520)	IEC 2B	0.14	10.7 m/s	8.5 m/s
1.2	V136-4.2 MW	82 (T3111520)	S (based on IEC 2B)	0.14	11.0 m/s	8.0 m/s
2.1	V136-4.0MW	82 (T885209)	IEC 2B	0.14	10.7 m/s	8.5 m/s
2.2	V136-4.2 MW	82 (T885209)	S (based on IEC 2B)	0.14	11.0 m/s	8.0 m/s
3.1	V136-4.0MW	112 (T887005)	IEC 2B	0.14	10.7 m/s	8.5 m/s
3.2	V136-4.2 MW	112 (T887005)	S (based on IEC 2B)	0.14	11.0 m/s	8.0 m/s
4.1	V136-4.0MW	117 (T887501)	IEC 2B	0.14	10.7 m/s	8.5 m/s
4.2	V136-4.2 MW	117 (T887501)	S (based on IEC 2B)	0.14	11.0 m/s	8.0 m/s

* The ID follows the hub height with its first digit, the second digit is only consecutive to identify the different configurations within one hub height